

**CITY OF RAYMORE**

100 Municipal Circle · Raymore, MO. 64083  
Phone · 816-892-3045 · Fax · 816-892-3093



**ADDENDUM NO. 2**

Willowind Gravity Sewer  
Project #20-345-201

All plan holders are hereby notified and agree by signature below, that the proposal includes consideration of the following changes, amendments, and/or clarifications and costs associated with these changes and are included in the proposal.

**Addendum No. 2 - Clarification**

- 1. The casing pipe can be placed underneath 58 Highway by either horizontal directional drilling or horizontally bored.
- 2. The casing pipe can be either restrained, C905 PVC or a steel casing. Steel thickness shall be a minimum of .188 inches.
- 3. The casing pipe line item should be bid as if rock will NOT be encountered between MH A-6 and MH A-7. If rock is encountered and it requires a change in equipment, method or causes a delay/lengthens the process, the City will negotiate a monetary change order with the contractor.

Any other questions regarding this proposal shall be submitted to Kim Quade, CPPB by email at kquade@raymore.com or by phone at (816) 892-3045. There will be no questions allowed after July 13, 2020 at 5 p.m.

I hereby certify that the above have been considered and associated costs have been included in this bid.

Company Name: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Address: \_\_\_\_\_

City, State, Zip: \_\_\_\_\_

Date: \_\_\_\_\_ Phone: \_\_\_\_\_

Signature of Bidder: \_\_\_\_\_

**ADDENDUM MUST BE SUBMITTED WITH BID**