

CITY OF RAYMORE

100 Municipal Circle · Raymore, MO. 64083
Phone · 816-892-3045 · Fax · 816-892-3093

**ADDENDUM NO. 2**

2020 Stormwater Improvements

Project #20-350-201

All plan holders are hereby notified and agree by signature below, that the proposal includes consideration of the following changes, amendments, and/or clarifications and costs associated with these changes and are included in the proposal.

Addendum No. 2 - Questions

1. On Crest Drive, is flowable fill required around the new box and new storm pipe?

Answer: No. Flowable fill is not required for Crest Drive

2. What are the City's testing requirements for this project? Is the City handling the testing? Contractor? If Contractor, what are the testing requirements considering the nature of the work.

Answer: The City will do all inspections. No concrete or asphalt testing is required.

Any other questions regarding this proposal shall be submitted to Kim Quade, CPPB by email at kquade@raymore.com or by phone at (816) 892-3045. There will be no questions allowed after July 20th, 2020 at 5 p.m.

I hereby certify that the above have been considered and associated costs have been included in this bid.

Company Name: _____

By: _____

Title: _____

Address: _____

City, State, Zip: _____

Date: _____ Phone: _____

Signature of Bidder: _____

ADDENDUM MUST BE SUBMITTED WITH BID