

**CITY OF RAYMORE**

100 Municipal Circle · Raymore, MO. 64083  
Phone · 816-892-3045 · Fax · 816-892-3093



**ADDENDUM NO. 1**

Municipal Circle Detention Improvements  
Project #20-266-202

All plan holders are hereby notified and agree by signature below, that the proposal includes consideration of the following changes, amendments, and/or clarifications and costs associated with these changes and are included in the proposal.

**Addendum No. 1 - Question and clarification.**

**1. Bid Opening Date**

The Bid Opening Date has been changed. Bids are due **Wednesday, November 4th at 10:00 a.m.**

**2. Project Completion Date**

Project completion has been changed to a fixed date. The date of completion is **May 31, 2021**

**3. Appendix A, Section 1 Anticipated Scope of Services; Installing an underground detention system; linear feet listed incorrectly.**

The correct length of the 96" pipe should be **474** feet as stated on the cover page of the plans.

**4. Question: Is there any rock anticipated to be encountered in excavation?**

Several Test pits were dug and rock was encountered at 1081+/-

**5. Alternatives: The basis for the design for this project is the 96", CMP system as shown in the plans, shop drawing examples and the RFP.**

Alternatives will be considered if they meet the following specifications:

- Provide 35,000 cubic feet of underground detention.
- Provide for water quality improvement for the first flush of a rain event.
- The components of the system must allow for a minimum cover of one foot of clean fill and an additional 4" of topsoil.
- The system must allow for the construction of the finished surface improvements as shown on page four of the plans.
- A qualification packet must be submitted with the bid packet for an alternative system to be considered. It must contain the following:
  - Shop drawings specific to this site/project.
  - Stormwater calculations
  - Detailed cost breakdown of the alternative vs. the Contech system.

**6. Attendees at Pre-Bids:**

Infrastructure Solutions  
Terry Snelling Construction  
Redford Construction  
Tasco LLC

Advanced Drainage Systems  
Hettinger Excavating  
ADS

Primetime  
Breit Construction  
Pyarmid Excavation

Any other questions regarding this proposal shall be submitted to Kim Quade, CPPB by email at kquade@raymore.com or by phone at (816) 892-3045. There will be no questions allowed after October 30, 2020 at 5 p.m.

I hereby certify that the above have been considered and associated costs have been included in this bid.

Company Name: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Address: \_\_\_\_\_

City, State, Zip: \_\_\_\_\_

Date: \_\_\_\_\_ Phone: \_\_\_\_\_

Signature of Bidder: \_\_\_\_\_

**ADDENDUM MUST BE SUBMITTED WITH BID**