

CITY OF RAYMORE

100 Municipal Circle · Raymore, MO. 64083
Phone · 816-892-3045 · Fax · 816-892-3093



ADDENDUM NO. 2

Rec Park Trail Replacement
Project #20-363-201

All plan holders are hereby notified and agree by signature below, that the proposal includes consideration of the following changes, amendments, and/or clarifications and costs associated with these changes and are included in the proposal.

Addendum No. 1 - Question and clarification.

1. Question: What is the depth of concrete to be removed?

Response: 4" Thick

2. Question: T-Pad size verification

Response: The pad is 12' long by 4' wide at one end, 6' wide at the other.

3. Question: Who is responsible for locates?

Response: The contractor is responsible for calling 1-800-Dig-Rite. The City will locate any private irrigation lines.

Please remember you must be a planholder with QuestCDN or the City of Raymore in order to submit a proposal on this project.

Pre-Bid Attendees:

- | | | |
|-----------------------|-----------------------------|--------------------------|
| DS Concrete | B. Dean Construction | Infrastructure Solutions |
| Spalding Constructors | Terry Snelling Construction | perfect Fence |
| JM Fahey | Phoenix Concrete LLC | Radmacher Bros. |
| SGI | Precision Construction | Amino Brothers |
| Freeman Concrete | Primetime Contracting | Tasco LLC |

Any other questions regarding this proposal shall be submitted to Kim Quade, CPPB by email at kquade@raymore.com or by phone at (816) 892-3045. There will be no questions allowed after November 16, 2020 at 5 p.m.

I hereby certify that the above have been considered and associated costs have been included in this proposal.

Company Name: _____

By: _____

Title: _____

Address: _____

City, State, Zip: _____

Date: _____ Phone: _____

Signature of Bidder: _____

ADDENDUM MUST BE SUBMITTED WITH PROPOSAL