

**CITY OF RAYMORE**

100 Municipal Circle · Raymore, MO. 64083  
Phone · 816-892-3045 · Fax · 816-892-3093



**ADDENDUM NO. 1**

Mazuma Force Main Replacement  
Project #22-378-201

All plan holders are hereby notified and agree by signature below, that the proposal includes consideration of the following changes, amendments, and/or clarifications and costs associated with these changes and are included in the proposal.

**Addendum No. 1 - Question and clarification.**

**1. Question:** Are fittings required to be domestic?

**Response:** No

**2. Question:** Will we be able to close the road off?

**Response:** Yes. Contractor will have to submit a traffic control plan for City approval.

**3. Question:** What is the maximum time to shut down the force main?

**Response:** Two to three days, if no rain.

**4. Question:** Is there a line item for a temporary reconnection?

**Response:** No, If needed we would do a change order

**Clarification:** C 905 DR 25 PVC is an acceptable alternative to ductile iron Pipe.

Any other questions regarding this proposal shall be submitted to Kim Quade, CPPB by email at kquade@raymore.com or by phone at (816) 892-3045. There will be no questions allowed after May 13, 2022 at 5 p.m.

I hereby certify that the above have been considered and associated costs have been included in this bid.

Company Name: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Address: \_\_\_\_\_

City, State, Zip: \_\_\_\_\_

Date: \_\_\_\_\_ Phone: \_\_\_\_\_

Signature of Bidder: \_\_\_\_\_

**ADDENDUM MUST BE SUBMITTED WITH BID**