

City of Raymore

100 Municipal Circle · Raymore, MO. 64083 Phone · 816-892-3045 · Fax · 816-892-3093

ADDENDUM NO. 2

155th Street Reconstruction 17-260-201

All plan holders are hereby notified and agree by signature below, that the bid includes consideration of the following changes, amendments, and/or clarifications and costs associated with these changes and are included in the bid.

Addendum No. 2 - Clarification

1. Clarification

- a. Striping is to be high-build paint with Type "L" glass beads, not epoxy.
- b. The limits of the project are from Madison to Kentucky and does not include the intersections themselves.
- c. The gravel driveways are to be leveled up with the new asphalt with gravel.
- d. The asphalt in the areas to be patched will be removed down to the subgrade. If the subgrade is excessively soft, the subgrade will be over-excavated and replaced with asphalt. Payment for all asphalt used in the patching process will be by the ton.
- e. Erosion control is subsidiary to the culvert line items. The contractor shall use silt fence or straw waddles to prevent soil from leaving the site.

I hereby certify that the above have been considered and associated costs have been included in this bid.

Company Name:		
	Phone:	
Signature of Bidd		

ADDENDUM MUST BE SUBMITTED WITH BID