

CITY OF RAYMORE

100 Municipal Circle · Raymore, MO. 64083
Phone · 816-892-3045 · Fax · 816-892-3093



ADDENDUM NO. 1

Permeable Paver Crosswalks
Project #18-295-201

All plan holders are hereby notified and agree by signature below, that the bid includes consideration of the following changes, amendments, and/or clarifications and costs associated with these changes and are included in the bid.

Addendum No. 1 - Clarification

- 1. Geogrid shall be MiraGrid 3XT or equivalent**
- 2. 6" Perforated Pipe shall be Perforated N-12 HDPE or equivalent**
- 3. Traffic Control:**

All streets may not be closed at the same time and may only be closed while under construction (2-3 weeks). Streets may be closed in the following groupings or lesser groupings:

- Darrowby- Mott- Skyline (Municipal Circle)
- Sunset North- High- Park- Arabian
- Sunset South- Woodson- Appaloosa

Pre-Bid Attendees:

Realm Construction	VF Anderson Builders	MSE Hardscapes
Tasco LLC	Gridiron Construction	Terry Snelling Construction
Breit Construction	Long's Lawn & Landscaping	

Any other questions regarding this proposal shall be submitted to Kim Quade, CPPB by e-mail at kquade@raymore.com or by phone at (816) 892-3045. There will be no questions allowed after April 27th, 2018 at 5 p.m.

I hereby certify that the above have been considered and associated costs have been included in this bid.

Company Name: _____

By: _____

Title: _____

Address: _____

City, State, Zip: _____

Date: _____ Phone: _____

Signature of Bidder: _____

ADDENDUM MUST BE SUBMITTED WITH BID